



737 South Third Street, Lincolnton, NC 28052-2100  
502.555.4181, 502.597.0488 Fax, www.lockett-farley.com  
Master Planning | Architecture | Engineering | Interior Design  
Design Build | Building Commissioning | Special Inspections

**Lockett & Farley**  
ARCHITECTURAL FIRM LICENSE NUMBER: 5088  
ENGINEERING FIRM LICENSE NUMBER: 1-0207  
© 2018



Academic Privatization  
Rivers Walk  
178 S. WATERS ST., BOONE, NC 28607

Table with 2 columns: #, Description. Includes fields for Date, Checked, and Description.

Table with 2 columns: MADE BY, CHECKED BY. Includes fields for Date, Date, and Drawing No. 2-E8.2.

PANEL: RPB3. LOCATION: CORRIDOR 3300. SUPPLY FROM: DPB. MOUNTING: FLUSH. ENCL: NEMA 1. VOLTAGE: 208Y/120 3Ø.4W. S.C. RATING: 22,000 AIC. BUS RATING: 100A MCB. BUS RATING: 225 A. GROUND BUS: Yes. NEUTRAL RATING: 100%. Includes circuit schedule table and load classification summary.

PANEL: RPB4. LOCATION: Space 288. SUPPLY FROM: DPB. MOUNTING: FLUSH. ENCL: NEMA 1. VOLTAGE: 208Y/120 3Ø.4W. S.C. RATING: 22,000 AIC. BUS RATING: 100A MCB. BUS RATING: 225 A. GROUND BUS: Yes. NEUTRAL RATING: 100%. Includes circuit schedule table and load classification summary.

PANEL: RPB5. LOCATION: Space 223. SUPPLY FROM: RPB4. MOUNTING: FLUSH. ENCL: NEMA 1. VOLTAGE: 208Y/120 3Ø.4W. S.C. RATING: 22,000 AIC. BUS RATING: 225 A. GROUND BUS: Yes. NEUTRAL RATING: 100%. Includes circuit schedule table and load classification summary.

PANEL: RPB6. LOCATION: Space 290. SUPPLY FROM: RPB5. MOUNTING: FLUSH. ENCL: NEMA 1. VOLTAGE: 208Y/120 3Ø.4W. S.C. RATING: 22,000 AIC. BUS RATING: 225 A. GROUND BUS: Yes. NEUTRAL RATING: 100%. Includes circuit schedule table and load classification summary.

PANEL: GB1. LOCATION: STAIR C. SUPPLY FROM: GB2. MOUNTING: SURFACE. ENCL: NEMA 1. VOLTAGE: 208Y/120 3Ø.4W. S.C. RATING: 22,000 AIC. BUS RATING: 225 A. GROUND BUS: Yes. NEUTRAL RATING: 100%. Includes circuit schedule table and load classification summary.

PANEL: GB2. LOCATION: Space 249. SUPPLY FROM: SDPB. MOUNTING: SURFACE. ENCL: NEMA 1. VOLTAGE: 208Y/120 3Ø.4W. S.C. RATING: 22,000 AIC. BUS RATING: 225 A. GROUND BUS: Yes. NEUTRAL RATING: 100%. Includes circuit schedule table and load classification summary.

PANEL: LP1A. LOCATION: ELECTRIC ROOM 'A' 112. SUPPLY FROM: DPA. MOUNTING: SURFACE. ENCL: NEMA 1. VOLTAGE: 208Y/120 3Ø.4W. S.C. RATING: 10,000 AIC. BUS RATING: 100A MLO. BUS RATING: 100 A. GROUND BUS: Yes. NEUTRAL RATING: 100%. Includes circuit schedule table and load classification summary.

PANEL: RPBZA. LOCATION: POOL ROOM 2G05. SUPPLY FROM: DPB. MOUNTING: SURFACE. ENCL: NEMA 1. VOLTAGE: 208Y/120 3Ø.4W. S.C. RATING: 10,000 AIC. BUS RATING: 100A MCB. BUS RATING: 100 A. GROUND BUS: Yes. NEUTRAL RATING: 100%. Includes circuit schedule table and load classification summary.

PANEL: RPB6. LOCATION: Space 223. SUPPLY FROM: RPB4. MOUNTING: FLUSH. ENCL: NEMA 1. VOLTAGE: 208Y/120 3Ø.4W. S.C. RATING: 22,000 AIC. BUS RATING: 225 A. GROUND BUS: Yes. NEUTRAL RATING: 100%. Includes circuit schedule table and load classification summary.

GENERAL NOTES - PANEL SCHEDULES:

- A. UNLESS SPECIFICALLY NOTED OTHERWISE, SIZE OF HOMERUNS AND BRANCH CIRCUIT WIRING FOR 120 VOLT CIRCUITS SHALL BE AS FOLLOWS: LENGTH, FEET HOME RUNS BRANCH CIRCUITS 0 TO 50 NO. 12 NO. 12 51 TO 100 NO. 10 NO. 12 101 TO 150 NO. 8 NO. 10
- B. PROVIDE MASTER KEYS LOCATIONS ON ALL PANELBOARDS LOCATED IN CORRIDORS AND OTHER PUBLIC SPACES.
- C. FOR APARTMENT PANEL SCHEDULES, REFER TO TYPICAL UNIT PLANS.

PANEL LEGEND table listing RPB3, RPB4, RPB5, RPB6, GB1, GB2, LP1A, RPBZA.